



**Barton Springs
Edwards Aquifer**
CONSERVATION DISTRICT

October 11, 2017

Via certified mail and email

Wet Rock Groundwater Services, LLC
317 Ranch Rd 620 South, Suite 203
Austin, TX 78734

RE: Administrative Completeness Review of Well Modification Applications submitted by Electro Purification LLC, for authorization to permanently complete seven (Bridges Wells No. 1, 2, 3, 4 and Odell Wells No. 1, 2, 3) previously drilled test wells proposed to produce from the Middle Trinity Aquifer.

Dear Mr. Kaveh Khorzad:

This letter is to inform you that as of **October 11, 2017**, the first 90-day period for the administrative completeness review of the above-reference application received on July 13, 2017 expired with the application remaining administratively incomplete. In accordance with District Rule 3-1.6(B), this letter serves to notify Electro Purification, LLC of the deficient information and documentation and that the application is granted a 90-day extension to allow further time for processing and administrative completeness review. **With the extension, the application will not be due to expire until January 9, 2018.**

Based on our review of the submitted permit application, the following information requirements have either not been satisfied or require additional information or clarification:

3-1.4(A)(7)(a) – Nature, Purpose, and Location

The applicant indicated that four wells (Bridges Wells No. 3 and 4 and Odell Wells No. 1 and 3) will be converted to domestic exempt wells. To ensure that the wells will be used for beneficial use and meet the exemption criteria, please provide information and documentation (e.g. construction plans for house etc.) as to when each well will be utilized to supply water to a house. Furthermore, describe the proposed receiving area for each well.

Also, please describe which wells you may consider designating as monitoring wells if District rules and permit provisions require that index wells be in place for long-term monitoring.

3-1.4(A)(7)(b) Pumpage Volume

Please indicate the timeframe in which pumps will be installed in the domestic exempt wells and the pumping rate for each well.

3-1.4(A)(7)(c) Well Construction Schematics

In order to streamline the review, please superimpose the existing/original well construction into the schematics. If possible, please include the geophysical logs in the schematics as well. Also, please indicate where there may be any deviations from the state well reports.

The schematics indicate that sulfate resistant grout (e.g. Type H) will not be used on the three PWS wells. Please provide written confirmation from TCEQ (email will suffice) that this type of grout is not acceptable for PWS wells.

Please provide the above requested information within **30 days** of the date of this letter. If you have any further questions or need clarification regarding the requested information, please feel free to contact my office by phone at 512/282-8441.

Sincerely,



John T. Dupnik, P.G.
General Manager

cc:

Electro Purification LLC
4605 Post Oak Place Dr.
Houston, TX 77027

Ed McCarthy
Jackson, Sjoberg, McCarthy & Townsend LLP
711 West 7th Street
Austin, Texas 78701

Bill Dugat
Bickerstaff Heath Delgado Acosta LLP
3711 S. Mo-Pac, Suite 300
Austin, TX 78746