

Water-Mart WSC

Historical Permitted Pumpage: 10,000,000 gallons/year

UDCP Appd Year: 2011
 Water Use For: Public Water Supply

Drought Stage Target Pumpage Volume

	Percentage of annual pumpage based on comparable well use	Baseline	Drought Stage Target Pumpage Volume				
			Water Con. Period 10% Reduction (Voluntary)	Alarm Stage 20% Reduction	Critical Stage 30% Reduction	Exceptional 40% Reduction	Emergency Response Period
September	10.0%	1,000,000	900,000	800,000	700,000	600,000	600,000
October	8.3%	830,000	747,000	664,000	581,000	498,000	498,000
November	7.0%	700,000	630,000	560,000	490,000	420,000	420,000
December	6.3%	630,000	567,000	504,000	441,000	378,000	378,000
January	6.3%	630,000	567,000	504,000	441,000	378,000	378,000
February	6.5%	650,000	585,000	520,000	455,000	390,000	390,000
March	6.6%	660,000	594,000	528,000	462,000	396,000	396,000
April	7.4%	740,000	666,000	592,000	518,000	444,000	444,000
May	8.0%	800,000	720,000	640,000	560,000	480,000	480,000
June	9.5%	950,000	855,000	760,000	665,000	570,000	570,000
July	12.1%	1,210,000	1,089,000	968,000	847,000	726,000	726,000
August	12.0%	1,200,000	1,080,000	960,000	840,000	720,000	720,000
Totals:			9,000,000	8,000,000	7,000,000	6,000,000	6,000,000